

APPENDIX L

DOH EXEMPTION LETTER FOR LT2ESWTR



STATE OF WASHINGTON

DEPARTMENT OF HEALTH

20435 72nd Ave. S., Suite 200, K17-12 • Kent, Washington 98032 -2358

July 2, 2007

GREG PETERKA
SKAGIT COUNTY PUD NO. 1
PO BOX 1436
MOUNT VERNON, WA 98273

Subject: Skagit County PUD No. 1-Judy Reservoir (ID# 79500)
Skagit County
Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR)
Grandfathered Source Water Data- Judy Reservoir Water Treatment Plant

Dear Mr. Peterka:

We have reviewed the grandfathered *Cryptosporidium* monitoring data that were received by EPA on April 27, 2007 and the monitoring location schematic received on June 22, 2007. These data include the results of 26 *Cryptosporidium* samples that were collected between January, 2004 and December, 2005. It is understood that you have submitted this data in lieu of collecting the source monitoring data required to comply with the LT2ESWTR. These data have been reviewed against the requirements of CFR 141.707 and are hereby APPROVED for the purposes of grandfathering.

The report indicates that your calculated *Cryptosporidium* bin concentration for your Judy Reservoir source is 0 oocysts/L, placing your source in bin 1. Under this bin classification no additional treatment for *Cryptosporidium* is required. You have satisfied the requirement for a *Cryptosporidium* bin classification report under CFR 141.710.

A second round of source water monitoring is required as part of the LT2ESWTR. The sampling plan for round 2 is due July 1, 2015 and sampling must start by October 1, 2015. Your bin classification may change based on the results of the second round of monitoring.

Please continue to send us copies of any items you submit to EPA regarding this rule. For more information regarding the rule, visit the LT2ESWTR website at www.epa.gov/safewater/disinfection/lt2.

If you have any questions regarding this letter, please contact me at (253) 395-6765.

Sincerely,

Nancy Feagin, P.E.
Regional Engineer
NW Drinking Water Operations

cc: Lorna Parent, Skagit County Health Department
Greg Hamilton, Skagit County PUD
Information Processing Management Center

